

BID BULLETIN NO. 2

PROJECT : COCONUT TISSUE CULTURE LABORATORY (PHASE 2)

LOCATION : Kalimudan Lane, UP Mindanao, Mintal, Tugbok, Davao City

OWNER : University of the Philippines Mindanao

BIDDER : _____ DATE : _____

Enclosed herewith are further instructions, clarifications, modifications and/or additions to the bidding documents for the above project:

1.0 ADDITIONAL DRAWINGS

The following plans are issued to the bidders to assist in their preparation of bids.

- Additional three(3) column along Grid line 1, 2, & 3
- Roof beam main bar reinforcement is suggested to change from 12mm to 16mm diameter bar and additional temperature bar at mid and end support.
- Change the specification of steel bar reflected in specification documents from grade 40 to grade 33.
- architectural facade design kindly see attached hard copy
- size of exterior wall from 6" thick with load bearing block 350 psi will be retain

Additional reference Plans	
Structural Plans	Hard Copy
Architectural Facade	Hard Copy

END OF BID BULLETIN NO. 2

Read and accepted as part of the Contract:

Bidder/Contractor