



UNIVERSITY OF THE PHILIPPINES MINDANAO

Shaping minds that shape the nation

INVITATION FOR NEGOTIATED PROCUREMENT

(DUE TO TWO FAILED BIDDINGS)

Supply of Equipment (UPS and Secure Vault System) for the ALAM-LSI Project PBM 2022-32

Item No.	Description Delivery Schedule / Place	Approved Budget (ABC)
Lot 1	High End Uninterruptible Power Supply (UPS) Delivery period: Thirty (30) to ninety (90) calendar days Delivery and Installation: CARIM Bldg., UP Mindanao Mintal, Tugbok District, Davao City	Php 500,000.00
Lot 2	Secure Vault System Delivery period: Thirty (30) to sixty (60) calendar days Delivery and Installation: CARIM Bldg., UP Mindanao Mintal, Tugbok District, Davao City	Php 100,000.00

1. UP Mindanao, through its Bids and Awards Committee (BAC), now invites technically, legally, and financially capable suppliers for the mentioned goods and services.
2. The mode of procurement for this procurement project is Negotiated Procurement due to two (2) failed biddings pursuant to Section 53.1 of the 2016 Revised Implementing Rules and Regulations (IRR) of Republic Act 9184 (RA 9184), otherwise known as the "Government Procurement Reform Act", including its Annex "H".

The BAC will engage in negotiations with a sufficient number of suppliers to ensure effective competition. The selection of the successful offer shall be based on the best and final offer that will be submitted on the date specified below, which could sufficiently meet the technical specifications.

3. Interested parties may obtain further information from the BAC Secretariat by electronic mail to bacgoods.upmin@up.edu.ph or through telephone.
4. Hereunder is the schedule of bidding activities:
Issuance and Availability of Negotiation Documents: **November 27, 2022**
Negotiation Meeting: **December 9, 2022 at 9AM** via Zoom
Note: Zoom link will only be provided upon request sent to the BAC Secretariat's email address: bacsecretariat.upmindanao@up.edu.ph.
Submission/Opening of Final Offer: **December 22, 2022 at 9AM.**

The Negotiation Documents may be downloaded from the PhilGEPS website and from the UP Mindanao website and may be obtained from the given address below upon payment of the applicable fee for the Bidding Documents, pursuant to the latest Guidelines issued by the GPPB, in the amount indicated in the table below:

Approved Budget for the Contract	Cost of Bidding Documents
P500,000.00 or less	P500.00
More than P500,000.00 up to P1M	P1,000.00
More than P1,000,000.00 up to P5M	P5,000.00

5. Bids must be submitted to the BAC through its Secretariat to the following address:

SPMO, Administration Building, UP Mindanao, Mintal, Davao City on or before the deadline.

Late bids shall not be accepted.

Online or electronic submission of bids is no longer allowed.

DOCUMENTARY REQUIREMENTS

I. Technical Component

- Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages) and
- Technical Specifications.

II. Financial Component

- Bid Form (each page should bear the ink signature of the authorized signatory)
- Price Schedule (each page should bear the ink signature of the authorized signatory), and
- Authority of the Signatory (Special Power of Attorney or Board Secretary's Certificate).

Each Bidder shall submit an original copy of the Technical and Financial Component of its Bid. Bidders are requested to submit two additional hard copies (Copy 1 and Copy 2) of the Technical and Financial Component of its Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

6. The University of the Philippines Mindanao reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract in accordance with Section 41 of the 2016 IRR of RA 9184, without thereby incurring any liability to the affected bidder or bidders.

You may contact the BAC Secretariat at the address above or by electronic mail to bacsecretariat.upmindanao@up.edu.ph for more details.


PROF. CLETO L. NAÑOLA JR.
 BAC Chair

BID FORM

Date : _____

Project Identification No. : _____

To: *[name and address of Procuring Entity]*

Having examined the Philippine Bidding Documents (PBDs) including the Supplemental or Bid Bulletin Numbers *[insert numbers]*, the receipt of which is hereby duly acknowledged, we, the undersigned, offer to *[supply/deliver/perform]* *[Lot No. and description of the Goods]* in conformity with the said PBDs for the sum of *[total Bid amount in words and figures]* or the total calculated bid price, as evaluated and corrected for computational errors, and other bid modifications in accordance with the Price Schedules attached herewith and made part of this Bid. The total bid price includes the cost of all taxes, such as, but not limited to: *[specify the applicable taxes, e.g. (i) value added tax (VAT), (ii) income tax, (iii) local taxes, and (iv) other fiscal levies and duties]*, which are itemized herein or in the Price Schedules,

If our Bid is accepted, we undertake:

- a. to deliver the goods in accordance with the delivery schedule specified in the Schedule of Requirements of the Philippine Bidding Documents (PBDs);
- b. to provide a performance security in the form, amounts, and within the times prescribed in the PBDs;
- c. to abide by the Bid Validity Period specified in the PBDs and it shall remain binding upon us at any time before the expiration of that period.

Until a formal Contract is prepared and executed, this Bid, together with your written acceptance thereof and your Notice of Award, shall be binding upon us.

We understand that you are not bound to accept the Lowest Calculated Bid or any Bid you may receive.

We certify/confirm that we comply with the eligibility requirements pursuant to the PBDs.

The undersigned is authorized to submit the bid on behalf of *[name of the bidder]* as evidenced by the attached *[state the written authority]*.

We acknowledge that **failure to sign each and every page of this Bid Form**, including the attached **Schedule of Prices**, shall be a ground for the rejection of our bid.

Name: _____

Legal capacity: _____

Signature: _____

Duly authorized to sign the Bid for and behalf of: _____

Date: _____

Technical Specifications

Item	Specification	Statement of Compliance
	<p>General terms for all lots</p> <p>For Equipment:</p> <p>1) The equipment must come from a credible manufacturer with support through a distributor in the country; and</p> <p>2) The equipment must be brand new and unused.</p>	<p>[Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data, as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder’s statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</p>

Item	Specification	Statement of Compliance
	<p>LOT 1: High End Uninterruptible Power Supply (UPS) ABC: Php 500,000.00</p> <p>Delivery period: Thirty (30) to ninety (90) calendar days</p> <p>Delivery and Installation: CARIM Bldg., UP Mindanao Mintal, Tugbok District, Davao City</p>	
	<p>Technical Specifications:</p> <ul style="list-style-type: none"> ● Rated power in W: 10000 ● Rated power in VA: 10000 ● Power factor: 1 (unity) ● Rack unit/s: 6U (rack-mounted) ● Battery type: Lead-acid battery ● Harmonic distortion: less than 2% ● Output frequency: 50/60 Hz +/- 3 Hz sync to mains ● Crest factor: 3:1 ● UPS type: Double conversion online ● Wave type: sine wave (pure) ● Bypass type: Internal bypass (automatic and manual) 	

	<ul style="list-style-type: none"> ● Phase: Single Phase ● Battery recharge time: At least 1.5 hours ● Battery voltage: +/- 192V (split battery referenced to neutral) ● Battery charger power: 1195 W rated ● Battery power in VAH: 1805 VAh runtime ● Run time or Backup time: 3 minutes 45 seconds at full load (10kW) ● Battery Type: Lead-acid battery ● Network Management: must be compatible with PowerChute UPS management software ● Output connection type <ul style="list-style-type: none"> ○ 6 IEC 60320 C13 ○ 3 IEC Jumpers ○ 4 IEC 60320 C19 ● Product Certification <ul style="list-style-type: none"> ○ CE ○ EAC ○ IRAM ○ RCM ○ VDE ● Standards <ul style="list-style-type: none"> ○ EN/IEC 62040-1:2019/A11:2021 ○ EN/IEC 62040-2:2006/AC:2006 ○ EN/IEC 62040-2:2018 ● Acoustic level: 55 dBA ● Heat dissipation: 1947 Btu/h ● IP Degree of protection: IP20 ● Surge energy rate: 480 J ● EU RoHS Directive Compliant ● Equipment Inclusion <ul style="list-style-type: none"> ○ CD with software ○ Documentation CD ○ Installation guide ○ Rack mounting hardware ○ Rack mounting brackets ○ Rack mounting support rails ○ Temperature probe ○ USB cable ○ Warranty card ○ Web/SNMP management card <p>Inclusions:</p> <ul style="list-style-type: none"> ● Delivery, installation, materials, labor costs, knowledge transfer, and configuration ● With at least 3 years repair or replacement (excluding battery) and 2 years for battery 	
--	--	--

	<ul style="list-style-type: none"> • Product demonstration (online or face-to-face) may be required during post-qualification <p>Other Notes:</p> <ul style="list-style-type: none"> • Electrical termination of wiring from the mains input to the UPS will be provided by the end-user • Supplier will just connect/splice the wiring from the mains input to the UPS <p>NOTE: PLEASE INCLUDE BROCHURE OF EQUIPMENT/ITEM, WITH ITS MAKE/MODEL/UNIT NUMBER AND SPECIFICATIONS. IF POSSIBLE, INCLUDE PERFORMANCE METRICS/REVIEWS.</p>	
<p>LOT 2: Secure Vault System ABC: Php 100,000.00 Delivery period: Thirty (30) to sixty (60) calendar days Delivery and Installation: CARIM Bldg., UP Mindanao Mintal, Tugbok District, Davao City</p>		
	<p>Technical Specifications:</p> <ul style="list-style-type: none"> • Exterior: Black galvanized steel walls and door; Concealed hinges and recessed door type; Stainless steel handle with emergency release; Watertight Fire resistant Pre-Drilled Mounting Holes & Hardware • Preferably with humidity and temperature sensor • Finish: Durable and scratch-resistant powder-coated interior and exterior finish; With air vents and insulation panels • Interior storage capacity: At least 8.5 cu.ft.; can fit at least A3-size documents • Dimensions: 1430 mm H x 508 mm W x 345 mm D • Safety features: • Key lock mechanism <ul style="list-style-type: none"> ○ Programmable digital lock ○ Override access keys ○ Motorized locking door bolts ○ Fail-safe lock/unlock during power outage ○ Fire Protection Up To 1400° F/760° C <p>Inclusions:</p> <ul style="list-style-type: none"> • Delivery, installation, materials, labor costs, knowledge transfer, and configuration • With at least 1 year warranty • Product demonstration (online or face-to-face) may be required during post-qualification <p>NOTE: PLEASE INCLUDE BROCHURE OF EQUIPMENT/ITEM, WITH ITS MAKE/MODEL/UNIT NUMBER AND SPECIFICATIONS. IF POSSIBLE, INCLUDE PERFORMANCE METRICS/REVIEWS.</p>	



NOTE: PLEASE INCLUDE BROCHURE OF EQUIPMENT/ITEM, WITH ITS MAKE/MODEL/UNIT NUMBER AND SPECIFICATIONS. IF POSSIBLE, INCLUDE PERFORMANCE METRICS/REVIEWS.

Price Schedule for Goods Offered from Within the Philippines

[shall be submitted with the Bid if bidder is offering goods from within the Philippines]

For Goods Offered from Within the Philippines

Name of Bidder _____ Project ID No. _____ Page ____ of ____

1	2	3	4	5	6	7	8	9	10
Item	Description	Country of origin	Quantity	Unit price EXW per item	Transportation and all other costs incidental to delivery, per item	Sales and other taxes payable if Contract is awarded, per item	Cost of Incidental Services, if applicable, per item	Total Price, per unit (col 5+6+7+8)	Total Price delivered Final Destination (col 9) x (col 4)
1	High-end UPS								
	Technical Specifications: <ul style="list-style-type: none"> • Rated power in W: 10000 • Rated power in VA: 10000 • Power factor: 1 (unity) • Rack unit/s: 6U (rack-mounted) • Battery type: Lead-acid battery • Harmonic distortion: less than 2% • Output frequency: 50/60 Hz +/- 3 Hz sync to mains • Crest factor: 3:1 • UPS type: Double conversion online • Wave type: sine wave (pure) • Bypass type: Internal bypass (automatic and manual) • Phase: Single Phase • Battery recharge time: At least 1.5 hours 		1						

	<ul style="list-style-type: none"> ● Battery voltage: +/- 192V (split battery referenced to neutral) ● Battery charger power: 1195 W rated ● Battery power in VAH: 1805 VAh runtime ● Run time or Backup time: 3 minutes 45 seconds at full load (10kW) ● Battery Type: Lead-acid battery ● Network Management: must be compatible with PowerChute UPS management software ● Output connection type <ul style="list-style-type: none"> ○ 6 IEC 60320 C13 ○ 3 IEC Jumpers ○ 4 IEC 60320 C19 ● Product Certification <ul style="list-style-type: none"> ○ CE ○ EAC ○ IRAM ○ RCM ○ VDE ● Standards <ul style="list-style-type: none"> ○ EN/IEC 62040-1:2019/A11:2021 ○ EN/IEC 62040-2:2006/AC:2006 ○ EN/IEC 62040-2:2018 ● Acoustic level: 55 dBA ● Heat dissipation: 1947 Btu/h ● IP Degree of protection: IP20 ● Surge energy rate: 480 J ● EU RoHS Directive Compliant ● Equipment Inclusion <ul style="list-style-type: none"> ○ CD with software ○ Documentation CD ○ Installation guide ○ Rack mounting hardware ○ Rack mounting brackets ○ Rack mounting support rails ○ Temperature probe ○ USB cable ○ Warranty card ○ Web/SNMP management card <p>Inclusions:</p>								
--	--	--	--	--	--	--	--	--	--

	<ul style="list-style-type: none"> • Delivery, installation, materials, labor costs, knowledge transfer, and configuration • With at least 3 years repair or replacement (excluding battery) and 2 years for battery • Product demonstration (online or face-to-face) may be required during post-qualification <p>Other Notes:</p> <ul style="list-style-type: none"> • Electrical termination of wiring from the mains input to the UPS will be provided by the end-user • Supplier will just connect/splice the wiring from the mains input to the UPS <p>NOTE: PLEASE INCLUDE BROCHURE OF EQUIPMENT/ITEM, WITH ITS MAKE/MODEL/UNIT NUMBER AND SPECIFICATIONS. IF POSSIBLE, INCLUDE PERFORMANCE METRICS/REVIEWS.</p>								
2	Secure Vault System								
	<p>SECURE VAULT SYSTEM Technical Specifications:</p> <ul style="list-style-type: none"> • Exterior: Black galvanized steel walls and door; Concealed hinges and recessed door type; Stainless steel handle with emergency release; Watertight Fire resistant Pre-Drilled Mounting Holes & Hardware • Preferably with humidity and temperature sensor • Finish: Durable and scratch-resistant powder-coated interior and exterior finish; With air vents and insulation panels • Interior storage capacity: At least 8.5 cu.ft.; can fit at least A3-size documents 		1						

	<ul style="list-style-type: none"> • Dimensions: 1430 mm H x 508 mm W x 345 mm D • Safety features: <ul style="list-style-type: none"> o Key lock mechanism o Programmable digital lock o Override access keys o Motorized locking door bolts o Fail-safe lock/unlock during power outage o Fire Protection Up To 1400° F/760° C <p>Inclusions:</p> <ul style="list-style-type: none"> • Delivery, installation, materials, labor costs, knowledge transfer, and configuration • With at least 1 year warranty • Product demonstration (online or face-to-face) may be required during post-qualification <p>NOTE: PLEASE INCLUDE BROCHURE OF EQUIPMENT/ITEM, WITH ITS MAKE/MODEL/UNIT NUMBER AND SPECIFICATIONS. IF POSSIBLE, INCLUDE PERFORMANCE METRICS/REVIEWS.</p>								
--	---	--	--	--	--	--	--	--	--

Name: _____

Legal Capacity: _____

Signature: _____

Duly authorized to sign the Bid for and behalf of: _____