

Republic of the Philippines
University of the Philippines Mindanao

Date: April 21, 2017

ADDENDUM NO. 01-2017

Name of Contract: **Supply of Air Conditioning Units**

This Addendum is issued to revise the Technical Specifications of Lot 1:

Unit	Item Description	Quantity
	LOT 1 consisting of the following:	
units	Aircon, Split Type, Wall Mounted, inverter 2HP, KJ/HR =28720, EER=13.6, Power Supply= 220-240 V/1Ø/60hz, Refrigerant=R410A, Inclusive of, but not limited to, the ff. materials for installation: Circuit breaker bolt-on 30amps 1Ø 230V w/ enclosure Nema3; THHN wire 8.0mm² stranded, copper lead free, max temp 90° celsius for wet and dry location, resistant to petroleum by product, chemicals agents & oils, and termite resistant 1/2" PVC Pipe) WITH ONE YEAR WARRANTY	13
units	Aircon, Split Type, Wall Mounted, inverter 2.5HP, KJ/HR =28720, EER=13.6, Power Supply= 220-240 V/1Ø/60hz, Refrigerant=R410A, Inclusive of, but not limited to, the ff. materials for installation: Circuit breaker bolt-on 30amps 1Ø 230V w/ enclosure Nema3, THHN wire 8.0mm² stranded, copper lead free, max temp 90° celsius for wet and dry location, resistant to petroleum by product, chemicals agents & oils, and termite resistant 1/2" PVC Pipe WITH ONE YEAR WARRANTY	5
units	Aircon, Split Type, floor Mounted, inverter 3HP or higher, BTU/H=38000, KJ/HR=40,9000, EER=12.3, Power supply=220-240V/1Ø/60hz,Refrigerant=R410A, Inclusive of, but not limited to, the ff. materials for installation: Circuit breaker bolt-on 40amps 1Ø 230V w/ enclosure Nema3 (outdoor), THHN wire 8.0mm² stranded, copper lead free, max temp 90° celsius for wet and dry location, resistant to petroleum by product, chemicals agents & oils, and termite resistant 1/2" PVC Pipe WITH ONE YEAR WARRANTY	14
units	Aircon, Split Type, floor Mounted, inverter 3HP or higher, BTU/H=38000, KJ/HR=40,9000, EER=12.3, Power supply=220-240V/1Ø/60hz,Refrigerant=R410A, Inclusive of but not limited to the ff. materials for installation: Circuit breaker bolt-on 40amps 1Ø 230V w/ enclosure Nema3 (outdoor), THHN wire 8.0mm² stranded, copper lead free, max temp 90° celsius for wet and dry location, resistant to petroleum by product, chemicals agents & oils, and termite resistant 1/2" PVC Pipe WITH ONE YEAR WARRANTY	1
units	Aircon, Window Type, 2.0HP, Manual, KJ/HR=25500; EER=9.6, Power Supply=230V, Energy Saving, efficient, heavy duty, good quality, White color, With installation and at least 1 year warranty	2
	TOTAL Approved Budget P2,682,000.00	

For guidance and information of all concerned.

Prof. VICENTE B. CALAG
Vice Chair, Bids & Awards Committee

Jag